

**TENDER NO** **GSL/REPL/004/DP**

**SUBJECT** **ANNUAL RATE CONTRACT FOR SUPPLY, INSTALLATION AND COMMISSIONING OF CNG CAR AND COMBO (CAR-BUS) DISPENSER PACKAGE AT CHURU, MANDI, PAURI GARWAL (RISHIKESH) & CHAMPAWAT GA**

**CORRIGENDUM NO** **02**

**DATED** **24-11-2022**

This has reference to the subject tender. The corrigendum to the subject tender is hereby issued. All participating bidders are requested to note the changes in respect of the subject tender.

S No	Tender Clause No	Page No.	Tender Conditions	Addition
1	2 (F) Bid Due Date & Time	04	25-11-2022 @ 1500 hrs. Bids should be submitted (hard copy) at Gasonet Services Limited.	30-11-2022 @ 1500 hrs. Bids should be submitted (hard copy) at Gasonet Services Limited. Office (Noida)
2	2 (J) Technical Bid Opening Due date & Time	05	25-11-2022 @15:00 hrs. at Gasonet Services Limited. Office (Noida)	30-11-2022 @ 15:30 hrs. at Gasonet Services Limited. Office (Noida)
3	F-12 of forms & format	97	Replies to Pre-Bid Queries	Additional bidder queries and their replies are attached as per Annexure-1

It is advised that the above may please be taken in consideration while submitting your offer. Please also note that this communication forms an integral part of the tender document and a duly acknowledged copy of the same is to be submitted along with technical bid.

All other terms and conditions of above referred tender remain un-altered.

**Resonance Energy Pvt. Ltd.**

**GASONET SERVICE (RJ) LIMITED**

Annexure-1

Tender No. : GSL/REPL/004/DP

Replies of Additional Pre Bid Queries

Name of Work : ANNUAL RATE CONTRACT FOR SUPPLY, INSTALLATION AND COMMISSIONING OF CNG CAR AND COMBO (CAR-BUS) DISPENSER PACKAGE AT CHURU, MANDI, PAURI GARWAL (RISHIKESH) & CHAMPAWAT GA's				Date / Time of Pre- Bid Meeting: 14/11/22
S. No.	Tender Clause No. / Annexures	DESCRIPTION	Bidders Comments / Queries	GSL/ REPL Reply
1	5.3. Utility Specification- Sub Clause- (ii) Page 6 of 30	Bidder has to provide & install Surge Protection device at the Junction Box of each Dispenser.	OEM make Power Card assembly has inbuilt protection for Power Spike/Surges. So there is no requirement of additional SPD. Requesting you to kindly consider the same.	Noted. May be consider during detail engineering
2	Clause 6. - Technical Specification Sub Clause 6.1 Page 8 of 30	Non-resettable and non-volatile totalizer up to 999999.99 for total CNG sold in kg with an independent battery backup	The facility of independent battery backup for totaliser is not present in Compac dispenser. Request to kindly exclude this clause from Compac scope.	Tender condtion prevails
3	Clause 6. - Technical Specification Sub Clause- 6.7 Page 9 of 30	All instruments power supply shall be of 24 V DC	OEM make Solenoid valve is operate on 230 V AC which is duly approved by competent authority PESO. Other than SOV, all other instruments power supply will be DC. Kindly accept the same.	Noted, However bidder to provide PESO and ATEX approval for the same.
4	Clause 6. - Technical Specification Sub Clause- 6.14 Page 10 of 30	The totalizer should be displayed on the Alpha Numeric Display at the press of a single button on the Keypad	In Compac standard design make dispenser totalizer can be displayed at Alpha Numeric Display by 5 times pressing the start button. So no separate single button required for Totalizer.	Noted and accepted
5	Clause 6. - Technical Specification Sub Clause- 6.49 Page 15 of 30	Tubing and valves (supply and erection) from Compressor to Dispenser is also in the Bidder's scope	Bidder will not provide tubing & valve from compressor to dispenser. we request your goodself to kindly consider tubing & valves etc. from compressor to dispenser in your scope and Exclude it from bidder scope.	Tender condtion prevails
6	Clause 6. - Technical Specification Sub Clause- 6.53 (IV)	All electrical equipment's shall be supplied with double-compression cable glands.	Double Compression Gland are only appicable to armour cables which is used for incoming Power supply cable to the dispenser .	Accepted, However bidder to provide PESO and ATEX approval for the same.
7	4.4 Delivery Period Page 6 of 108	08 Weeks from the Date of issue of LOA / FOA / Release Order.	Delivery period shall be 16 weeks	Tender condtion prevails
8	G EMD Page 4 of 108	EMD INR 6,42,967/- in form of DD or PBG (Refundable).	Being a Medium Enterprise provision of MSE benefits are applicable so we will not submit EMD for the same. Notification is attached for refrence. Kindly confirm.	Tender condtion prevails
9	11 WARRANTY SERVICING Page 19 of 30	The suppliers should provide a warranty period of 12 months from the date of commissioning and final site acceptance of Dispenser or 24 months from the date of receipt of material site, whichever is earlier.	warranty will be concedered 12 month from commissioning	Tender condition prevails

S. No.	Tender Clause No. / Annexures	DESCRIPTION	Bidders Comments / Queries	GSL/ REPL Reply
10	1.3Preventive Maintenance: Contractor's Scope: Page 25 of 30	List of mandatory spares to be available with the Contractor every time (excluding Parts mentioned in Serial No. 6) strictly but not limited to are mentioned here.	sufficient spares to be kept at site based on complaint analysis.	Tender condition prevails
11	1.3Preventive Maintenance: Contractor's Scope: Page 26 of 30	Preventive maintenance will be carried out on Monthly basis during non-peak hours in consultation with EIC. Any maintenance that needs to be taken up shall be well planned in advance with due approval of EIC.	PM TO BE DONE ONE IN 3 MONTHS	Tender condition prevails
12	Break down Repair: Contractor Scope: Page 27 of 30	The service personnel will report to the call site within 2 hours from the time of receiving service call in CHURU,MANDI, PAURI GARWAL (RISHIKESH) & CHAMPAWAT GA site or at whatever site dispensers are installed (Prior Information will be provided for location of installation of Dispensers).	request to considered downtime of 8 hour	Tender condition prevails
13	Break down penalty: (During AMC Period) Page 29 of 30	Penalty of Rs2500 towards non availability of mandatory spares at operational sites.	penalty should not be imposed in such cases	Tender condition prevails
14	Break down penalty: (During AMC Period) Page 29 of 30	Penalty for 1 hour delay in reaching at all site (ie, within 3 hours instead of 2 hours) - Rs 500/- per arm per dispenser.	penalty should not be imposed in such cases	Tender condition prevails
15	Break down penalty: (During AMC Period) Page29 of 30	Penalty for 2 hour delay in reaching at all site (ie, within 4 hours instead of 2 hours) - Rs 1000/- per arm per dispenser.	penalty should not be imposed in such cases	Tender condition prevails
16	VOLUME- I of II SECTION - I	Calibration at site	It is bidders understanding that Statutory fees for On site stamping from local W&M department of CNG Dispensers shall be in scope of owner prior to commencement of commercial sale. Bidder shall only provide technical support during stamping. This is standard clause of all CGD companies. Please confirm	Statutory clearance from W&M India for the field installation before start of commercial operation of each dispenser as define in the tender for repective Gas/Cities is in the scope of bidder.